

OPERATING MANUAL



MUFFLE BOX FURNACE

BFMF-1100-3A





www.biolabscientific.com

INDEX

1. DEFINITION	2
2. SAFETY	2
2.1 PROPER OPERATION	3
2.2 OPERATION IN SAFE CONDITIONS	4
3. FIRST HEATING	. 5
4. DISPLAY & MENU	6
4.1 START & STOP FOR HEATING	7
4.2 FOLLOWING, ENTERING & CHANGING PARAMETERS	7
4.3 MENU	8
4.4 BUTTONS	9
APPENDIX-1 Technical Specifications	. 10
APPENDIX-2 Control Unit Features	. 12

1. DEFINITION

Series are laboratory type heating furnaces. Heating is performed up to 1100°C. This temperature is maximum temperature; continuous working temperature & adjustable temperature is 1050°C on these furnaces.

2. SAFETY

Heating furnace may harm operating people or surrounding any other materials, unless this operating manual is applied during operating process.

Thus;

-Periodical maintenance should be applied.

-Cautions against accidents should be main concern of operators.

-All operating directives, warnings and recommendations in this operating manual have to be followed and applied carefully.

Unless operating directives, warnings and recommendations in this operating manual are followed and applied, company Biolab is not dedicated for the accidents that may occur.

2.1 PROPER OPERATION

Muffle Furnace can reach up to 1100°C. Thus materials that can stand up to 1100°C can be heated in the chamber. The conditions that should be considered during operating or the points which are the reason no to start operational process are as follows,

• Furnace is not started, if there is any living thing in the chamber.

• Any burning, flammable, exploding, poisoning, (Benzene, LPG, Acetylene etc.) material that may harm when it is heated etc. is not stored or put inside the chamber. These types of materials should be kept away from the furnace.

• Outside case of the furnace may be hot. It should be considered. Especially, when the furnace is heated above 1000°C and if it is kept above this temperature 30 minutes or more, you shouldn't touch to outside case/surfaces without using gloves.

• Instant high heat should be considered, when the front door is open.

• Electronic and/or Electrical components may create induction current or magnetic field. It may harm any electronic equipment surrounding the furnace. Especially cardiac pacemaker users should be away from the furnace.

• It should not be operated in closed environments such as in cupboard etc.

• Furnace should not be operated by multi plug in tools. It should be operated by stationary plugs which are mounted on the wall.

• Electricity plug have to be grounded.



Explosive, flammable, burning, poisonous materials, don't heat up.





Instant high temperature, when the front door is opened.

2.2 OPERATION IN SAFE CONDITIONS

"Contribute in to SAFETY CAUTIONS in the work shop."

Please obey to safety rules. Please inform responsible person, as soon as you notice any abnormal condition for the furnace.



Please use protective glass or protective gloves, when you are working.

Don't let non-permitted person contact to any electrically alive parts. Possible electrically alive parts should be processed by responsible persons and by experts. Cables should be protected against/away from any heat, oil, oily material, sharp tools and materials. Cables should be kept away from furnace surface. Any cable may kill, if any parts of the cable are broken / damaged or cable touches on to the

furnace surface. Any broken cable should be replaced by the new one. - Danger of life due to electrical shock.

DANGER



- Danger of life due to electrical shock.

DANGER

To touch in to the electrically alive parts may kill, if cable is broken or damaged. Be aware of the environmental affects: Don't use electrical tools, equipment and machines in wet circumstances. Keep light intensity enough to make easier for the working people. Plug off the machine, before any cleaning, repair and maintenance process.

3. FIRST HEATING

Following conditions should be considered, directions must be applied step by step, and the importance of the first heating process should be kept in mind, Furnace is operated and heated up for the first time.

3.1-Enough free field, surrounding the furnace should be kept. Recommended distance is minimum 30 cm. This free space will increase the furnace performance because of air circulation. At the same time, any fire or explosion danger which may occur due to any material left around the furnace. Please don't forget, when the furnace reaches to high temperatures, the surface of the furnace reaches to high temperatures too. Any flammable and explosive material which is close to furnace can be a reason for the fire or explosion danger.

3.2-Electricity plug should have proper ground connection and plug should have proper capacity (Cable thickness) according to maximum ampere of the furnace.


3.3-Some gas and fumes due to some chemicals which is used on the electronic parts, in the isolation materials and due to outer furnace surface paint can be harmful if it is breathed directly, during the first heating process. Protective glasses and breathing masks should be definitely used, during first heating and very good air circulation in the working room should be kept.

3.4-During the first heating up process, furnace should be heated up according to following temperaturetime table

Heating up to 1100°C Waiting for 1 hour

This procedure can be completed Programs easily.

Please don't touch furnace without gloves, especially during first heating process, due to hot surfaces.



4. DISPLAY & MENU

Figure 1

Control panel includes 3 buttons (B1, B2, B3), green led and red led (L1, L2) and 3 digit display. If you see green led (L1) is on, your furnace is ready to start without any problem and the red light (L2) starts, if you start to heat the furnace. When the heating ends, the red led also turn off. Sound warning is the indication of starting the heating, level changes and finishing the heating procedure.

User interface (Keypad) has two different mode. First one is to understand the status/conditions of the furnace. Point led is turned off during the status mode. Unless you press a button, inner temperature is indicated on the display. If you start to heating and if you press B1 or B2, heating level and heating program can be followed via display.

4.1 START & STOP FOR HEATING

Heating is started, if you press 3-4 seconds ''START'' (B1) button during the Point Led is turned off. Sound warning indicates the initiation of heating and working program number is displayed for 3 seconds and main display is followed (That means inner temperature is displayed automatically). At the same time red led (L2) is turned on.

If B1 button is pressed short, actual level of heating procedure is displayed for 2 seconds, these are;

1-First level heating 2-First level waiting

1-Second level heating 2-Second level waiting

It is possible to change the program parameters, even the heating continues. But of course this is valid for the coming steps.

Heating is stopped, if you press ''STOP'' (B2) button long. (3-4 seconds). Sound warning indicates that you stop the furnace and red led (L2) is turned off.

Note: When energy cut off the working program continues to work, if the energy cut off occurs and supplied again.

4.2 FOLLOWING, ENTERING & CHANGING PARAMETERS

Second mode is to follow and to change the parameters of the heating procedure. Point led at the right bottom of display is turned on.

This mode is initiated when B3 is pressed short. If up or down arrows (B1 & B2) are pressed when the point led is turned on, you follow the each parameters of the program. Parameter which is wanted to be displayed appears and one second later set value appears at the display. B1 and B2 buttons are used to display other parameters.

Parameter can be changed, if B3 button is pressed long and the value starts to blink. B1 and B2 are the buttons to decrease or increase the values. To save the value, B3 is pressed long again while the value is blinking. The value is not saved, if B3 button pressed short and blinking is stopped.

4.3 MENU

P00 mode activates the program which will be displayed and set. Activated menu options depending on the selection of P00 are shown here-below. Parameters of any other program can be changed by changing P00, while the selected program is working.

4.3.1 MTS SERIES PX CONTROL PARAMETERS

Parameter No Parameter Detail	Value Range	
----------------------------------	----------------	--

P11	SET VALUE TEMPERATURE [C] 1 st PROG 1 st . STEP	
P12	SET VALUE WAITING TIME [Min.] 1 st PROG 1 st . STEP	1 - 999
P15	HEATING RATE [C/min]	5 - 25

Table 1

Parameters above can be set for PX Control Unit. Parameter selection mode appears when the B3 button is pressed (Point led at the bottom right turns on) and working temperature P11, waiting time P12 and heating rate P15 selection can be implemented.

4.3.2-MTS SERIES PX CONTROL UNIT MENU

PX Control Unit menu is different depending on P00 selection as follows, IF P00 "1" $\,$

Parameter No	Parameter Detail	Value Range
P00	Program Selection	1-2
P01	Program No (Selected)	
P02	Step No	1-4
P03	Cumulative Working Hour/10	
P11	VALUE TEMPERATURE [C] 1 ST PROG 1 ST . STEP	50 - 1050
P12	VALUE WAITING TIME [min.] 1 ST PROG 1 ST . STEP	1 - 999
P13	SET VALUE TEMPERATURE [C] 1 ST PROG 2 ND STEP	50 - 1050
P14	VALUE WAITING TIME [min.] 1 ST PROG 2 ND STEP	1 - 999
P15	HEATING RATE [C/min]	3 - 20

Table 2 IF P00 "2"

Parameter No	Parameter Detail	Value Range		
P00	Program Selection	1-2		
P01	Program No (Selected)			
P02	Step No	1-4		
P03	Cumulative Working Hour / 10			
P21	VALUE TEMPERATURE [C] 2 ND PROG 1 ST STEP	50 - 1050		

P22	VALUE WAITING TIME [min.] 2 ND PROG 1 ST STEP	1 - 999
P23	SET VALUE TEMPERATURE [C] 2 ND PROG 2 ND STEP	50 - 1050
P24	VALUE WAITING TIME [min.] 2 ND PROG 2 ND STEP	1 - 999
P25	HEATING RATE [C/min]	3 - 20

Table 3

Any other parameter set can be made, while the selected program is working. It does not affect the behavior of working program.

4.4 BUTTONS

	Status Mode	e	Heating Mo	leating Mode Parameter Mode			Parameter Set		
Butto n	Short Press	Long Press	Short Press	Long Press		Short Press	Long Press	Short Press	Long Press
B1	Not Applicable	Start	Step No	Program No		Parameter Advance	Parameter Advance	Increase the Value	Decrease the Value
B2	Not Applicable	Not Applicable	Not Applicable	ISton I		Parameter Back	Parameter Back	Increase the Value	Decrease the Value
В3	Parameter Mode	Not Applicable	Parameter Mode	Not Applicable		Status Mode	Parameter Selection	Out without saving	Saving

Table 4

APPENDIX-1 Technical Specifications

STEP 1 Maximum Working Temperature						
		11	00°C	•		
STEP 2 Choose	Your Volume			1		
	3 Liter	5 Liter	7 Liter	16 Liter	30 Liter	Custom
Continuous Working Temperature	1050°C	1050°C	1050°C	1050°C	1050°C	1050°C
Inner Chamber Dimensions [mm] WxHxD	130x105x230	150x150x225	180x160x260	240x200x345	300x250x395	Upon your request
Product Outer Dimensions [mm] WxHxD	384x470x475	404x515x475	434x525x505	494x565x590	554x615x640	Upon your request
Net Weight [kg]	22	24	28	38	47	Upon your request
Power [W]	1.350	1.600	2.000	3.000	3.900	Upon your request
Max. Current [A]	7	8	9	14	18	Upon your request
Electrical Connection	1 Phase	Upon your request				
Heating Element	Fe-Cr-Al	Fe-Cr-Al	Fe-Cr-Al	Fe-Cr-Al	Fe-Cr-Al	Fe-Cr-Al
Thermocouple Type	К Туре					
Heating Element Placement	Embedded into brick walls					
Inner Insulation Material	Ceramic Fibre Board or Insulating Fire Brick					
Front Face Insulation Material	Ceramic Fibre Board					
Door Insulation Material	Ceramic Fibre Board					
Housing Material	Steel Sheet					
Housing Coating	Epoxy powder coating	Epoxy powder coating	Epoxy powder coating	Epoxy powder coating	Epoxy powder coating	Epoxy powder coating
Chimney	None or Basic Tube Chimney on top					
Lockable Door Handle	Sidewards	Sidewards	Sidewards	Sidewards	Sidewards	Sidewards
Gross Dimensions [mm] WxHxD	425x640x515	445x685x515	475x695x545	535x735x630	595x785x680	Upon your request
Gross Weight [kg]	35	36	41	46	59	Upon your request

APPENDIX-2 Control Unit Features

Control Unit Software	EXTENDED Px
Software Based PID Control	YES
Display	7 Segment / 4 Digit
Heating Program with	4 steps
Custom Preset Program	2
Heating Rate °C/min.	5-25
Date & Time	NO
Maximum Waiting Time	9999 min
Auto Start at Certain Date	NO
Show Remaining Waiting Time	NO
Skip the Waiting Step	NO
Temperature Calibration via Menu (±10°C)	NO
Sound Warnings at Step Changes	YES
Sound Warning at the End of the Program	YES
Total Working Hour Counter	NO
Calculator for Average Working Temperature	NO
Instantaneous Energy Consumption Indicator	NO
Target Temperature Display	NO
Step Indicator	YES
Burst Heating Mode	NO
Descriptive Error Indicator	NO
Temperature Control Accuracy***	±1°C
Measurement Accuracy	±1°C
Inner Volume Temperature Homogenity	±10°C
Control Unit Overheating Sensor	YES
Over Heating Cut Off	YES
PC Connection Kit	OPTIONAL
Warranty Period	1 Year



Biolab Scientific Ltd.

Trillium Executive Center, East Tower, 675 Cochrane Dr, Markham, Ontario L3R 0B8, Canada Email: info@biolabscientific.com | Website: www.biolabscientific.com